Henry Clay Boiler Explosion.

On the morning of October the 11th, at about 7.30 o'elock, one of the most disastrous boiler explosions which has occurred in the his tory of mining, happened at the Henry Clay colliery. The plant, which was almost a new one, contained 34 cylinder boilers. Twentyseven of these, without any apparent cause, exploded, killing 7 men and injuring 2, and utterly demolishing the boiler house, besides doing damage to the surrounding buildings. Boiler experts from all sections of the country visited the scene, but none could give any satisfactory reason, or no two agree, as to the cause of the explosion. All agreed, however, that the material in the boilers was first-class, and that the explosion was not due to this cause. A strange thing which may be mentioned was that 15 boilers on one end and 12 on the other, exploded, while 7 in the centre remained in position and did not explode. The closest investigation on the part of the company and also by the coroner's jury, failed to place the cause, consequently it will have to be classed among the many of the strange happenings for which no satisfactory reason can be assigned.

TABLE A-Compa	rative Statement of	of Fatal	Casualities from	n Various
Causes that	Occurred During t	he Years	1892, 1893 and 1	894.

	1892	1893	1894
Suffocated by smoke from mine fire,	$\begin{array}{c} & & & \\ & & & 7 \\ & & 16 \\ & 10 \end{array}$	 5 30 15	5 6 27 12
Falling down slopes and shafts, Breaking of ropes and chains, Explosion of blasting materials, Kicked by mules,	3 1 5		
Balling down schutes,			3 - 5
Totals,	45	77	78